



**Jim Doyle, Governor**  
**Jack L. Fischer, A.I.A., Secretary**

August 6, 2008

PERFECTION CORPORATION  
DAVID ROBISON  
222 LAKE STREET  
MADISON OH 44057-3189

Re: Description: PIPES, POLYPROPYLENE  
Manufacturer: PERFECTION CORPORATION  
Product Name: PERFECTION RELIEF VALVE RUN-OFF TUBES (RVRTS)  
Model Number(s): 1" TOP MOUNT AND 1" SIDE MOUNT  
Product File No: 20080302

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30(4) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2013.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may only be used on temperature and pressure relief valves with a 105,000 BTU/HR rating or less.

This approval supersedes the approval issued on August 26 2003 under product file number 20030391.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030391.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson  
Plumbing Product Reviewer  
Phone: 608-266-6742  
Fax: 608-267-9566  
E-mail: Jerry.Thompson@wi.gov